


Prüfbericht-Nr.: <i>Test report no.:</i>	CN22JT0Z 001	Auftrags-Nr.: <i>Order no.:</i>	170321700	Seite 1 von 13 Page 1 of 13
Kunden-Referenz-Nr.: <i>Client reference no.:</i>	-	Auftragsdatum: <i>Order date:</i>	2022.11.04	
Auftraggeber: <i>Client:</i>	FOSHAN SHUNDE ZEALUX ELECTRICAL APPLIANCES CO., LTD. No.2-8, No.9 Road, Science and Technology zone, Xingtan Industrial Park, Xingtan Town, Shunde District, 528325 Foshan City, Guangdong P.R. China			
Prüfgegenstand: <i>Test item:</i>	Heat pump space heater			
Bezeichnung / Typ-Nr.: <i>Identification / Type no.:</i>	XAH10Csi32, ALSAVO HEAT 10i			
Auftrags-Inhalt: <i>Order content:</i>	EU energy performance test			
Prüfgrundlage: <i>Test specification:</i>	COMMISSION REGULATION (EU) No 813/2013 COMMISSION DELEGATED REGULATION (EU) No 811/2013 COMMISSION REGULATION (EU) 2016/2282 COMMISSION DELEGATED REGULATION (EU) 2017/254			
Wareneingangsdatum: <i>Date of sample receipt:</i>	2022.11.04			
Prüfmuster-Nr.: <i>Test sample no.:</i>	A003382697-001			
Prüfzeitraum: <i>Testing period:</i>	2022.11.04 – 2023.05.22			
Ort der Prüfung: <i>Place of testing:</i>	TÜV Rheinland (Guangdong) Ltd.			
Prüflaboratorium: <i>Testing laboratory:</i>	TÜV Rheinland (Guangdong) Ltd.			
Prüfergebnis*: <i>Test result*:</i>	Pass			
geprüft von: <i>tested by:</i>	genehmigt von: <i>authorized by:</i>			
Datum: <i>Date:</i> 2023.05.22	Signed by: Felix Tong		Ausstellungsdatum: <i>Issue date:</i> 2023.05.22	Signed by: Stone Shi
Stellung / Position: Project Engineer			Stellung / Position: Reviewer	
Sonstiges / <i>Other:</i>	This report is only for heating capacity test and sound power level test.			
Zustand des Prüfgegenstandes bei Anlieferung: <i>Condition of the test item at delivery:</i>	Prüfmuster vollständig und unbeschädigt <i>Test item complete and undamaged</i>			
* Legende: P(ass) = entspricht o.g. Prüfgrundlage(n) F(ail) = entspricht nicht o.g. Prüfgrundlage(n) N/A = nicht anwendbar N/T = nicht getestet				
* Legend: P(ass) = passed a.m. test specification(s) F(ail) = failed a.m. test specification(s) N/A = not applicable N/T = not tested				
<p>Dieser Prüfbericht bezieht sich nur auf das o.g. Prüfmuster und darf ohne Genehmigung der Prüfstelle nicht auszugsweise vervielfältigt werden. Dieser Bericht berechtigt nicht zur Verwendung eines Prüfzeichens. <i>This test report only relates to the a. m. test sample. Without permission of the test center this test report is not permitted to be duplicated in extracts. This test report does not entitle to carry any test mark.</i></p>				

V05

Testing results summary		
Model designation	XAH10Csi32	
Function	Heating (Average)	
Outlet temperature	35	55
Design load (kW)	7.3	7.7
Annual energy consumption (kWh)	3296	4825
Seasonal space heating energy efficiency	180	128
Energy class	A+++	A++

Summary of testing

- The appliance was evaluated capacity test according to EN 14825:2013 and EN 14825:2022.
- The appliance was tested at outlet temperature 35°C and 55°C.
- The capacity test method is air enthalpy method.
- The appliance was evaluated sound power level test according to EN 12102:2013 and EN 12102-1:2022.
- All tests were performed on the model XAH10Csi32.
- The test location is below.
 For heating capacity test
 TÜV Rheinland (Guangdong) Ltd.
 No.199 Kezhu Road, Guangzhou Science City Guangzhou 510663 China
 For sound power level test
 CVC Testing Technology Co., Ltd.
 No.3, Tiantaiyi Road, Kaitai Avenue, Science City, Guangzhou, Guangdong, P.R. China

Test sample particulars

Classification of installation and use: Fixed appliance

Type of the appliance: Air to water heat pump

Function of the appliance: Space heating

Heating season (heating function applicable).....: Average

Possible test case verdicts:

- test case does not apply to the test object: N/A

- test object does meet the requirement: P(Pass)

- test object does not meet the requirement: F(Fail)

Testing.....:

Date of receipt of test item.....: See cover page

Date (s) of performance of tests.....: See cover page

General product information

1. The appliance is air to water heat pump for space heating which installed at outdoor.
2. The appliance incorporates water pump.

Model description:




All models are identical to each other except for model name.




The information of compressor, fan motor and water pump are listed as below.

Object / part No.	Manufacturer/ trademark	Type / model	Technical data
Compressor	Guangzhou Meizhi Compressor Ltd.	KTM240D57UMT	Rated Voltage:DC156V; 180Hz ;R32
Fan motor	Wolong Electric Group Co., Ltd.	ZWB378D02B	DC310V,8P, 120W,880r/min
Water pump	HEFEI XINHU CANNED MOTOR PUMP CO.,LTD	GPD25-6S	AC230V/50Hz 100w class H

DRAFT

Rating labels and marking:

AIR SOURCE HEAT PUMP	
Model	XAH10Csi32
Rated heating capacity	10kW
Rated current	16A
Power supply	220-240V~ 50Hz
Advised water flux	1.7m ³ /h
Max. water pressure	0.3MPa
Water connection	G1"
Electric shock prevention	Class I
Waterproof protection	IPX4
Max. allowable pressure(discharge)	4.5MPa
Max. allowable pressure(suction)	1.5MPa
Refrigerant (R32)	1.5kg
CO2 equivalent	1.01tonnes
Net weight	78kg
FOSHAN SHUNDE ZEALUX ELECTRICAL APPLIANCES CO., LTD. No.2-8, No.9 Road, Science and Technology Zone, Xingtan Industrial Park, Xingtan Town, Shunde District, 528325 Foshan City, Guangdong P.R. China	
Contains fluorinated greenhouse gases. Hermetically sealed system.	
  	

AIR SOURCE HEAT PUMP	
Model	ALSAVO HEAT 10i
Rated heating capacity	10kW
Rated current	16A
Power supply	220-240V~ 50Hz
Advised water flux	1.7m ³ /h
Max. water pressure	0.3MPa
Water connection	G1"
Electric shock prevention	Class I
Waterproof protection	IPX4
Max. allowable pressure(discharge)	4.5MPa
Max. allowable pressure(suction)	1.5MPa
Refrigerant (R32)	1.5kg
CO2 equivalent	1.01tonnes
Net weight	78kg
FOSHAN SHUNDE ZEALUX ELECTRICAL APPLIANCES CO., LTD. No.2-8, No.9 Road, Science and Technology Zone, Xingtan Industrial Park, Xingtan Town, Shunde District, 528325 Foshan City, Guangdong P.R. China	
Contains fluorinated greenhouse gases. Hermetically sealed system.	
  	

COMMISSION REGULATION (EU) No 813/2013 COMMISSION DELEGATED REGULATION (EU) No 811/2013			
Clause	Requirement - Test	Result - Remark	Verdict

COMMISSION REGULATION (EU) No 813/2013			
Article 1	Subject matter and scope		P
1	This Regulation establishes ecodesign requirements for the placing on the market and/or putting into service of space heaters and combination heaters with a rated heat output heater ≤ 400 kW including those integrated in packages of space heater, temperature control and solar device or packages of combination heater, temperature control and solar device as defined in article 2 of Commission Delegated Regulation (EU) No 811/2013.		P
2	This Regulation shall not apply to: (a) heaters specifically designed for using gaseous or liquid fuels predominantly produced from biomass; (b) heaters using solid fuels; (c) heaters within the scope of Directive 2010/75/EU of the European Parliament and of the Council; (d) heaters generating heat only for the purpose of providing hot drinking or sanitary water; (e) heaters for heating and distributing gaseous heat transfer media such as vapour or air; (f) cogeneration space heaters with a maximum electrical capacity of 50 kW or above. (g) heat generators designed for heaters and heater housings to be equipped with such heat generators placed on the market before 1 January 2018 to replace identical heat generators and identical heater housings. The replacement product or its packaging shall clearly indicate the heater for which it is intended.		N/A
Article 3	Ecodesign requirements and timetable		P
1	The ecodesign requirements for heaters are set out in Annex II.		P
2	Each ecodesign requirement shall apply in accordance with the following timetable:		P
	(a) from 26 September 2015: (i) heaters shall meet the requirements set out in Annex II, points 1(a), 3 and 5; (ii) combination heaters shall meet the requirements set out in Annex II, point 2(a);		N/A

COMMISSION REGULATION (EU) No 813/2013													
COMMISSION DELEGATED REGULATION (EU) No 811/2013													
Clause	Requirement - Test											Result - Remark	Verdict
	(a) from 26 September 2017: (i) electric space heaters, electric combination heaters, cogeneration space heaters, heat pump space heaters and heat pump combination heaters shall meet the requirements set out in Annex II, point 1(b); (ii) combination heaters shall meet the requirements set out in Annex II, point 2(b);												P
	(a) from 26 September 2018 heaters shall meet the requirements set out in Annex II, point 4(a).												N/A
3	Compliance with ecodesign requirements shall be measured and calculated in accordance with the requirements set out in Annex III.												P
Annex II	Ecodesign requirements												P
1	Requirements for seasonal space heating energy efficiency												P
	(a) From 26 September 2015 the seasonal space heating energy efficiency and useful efficiencies of heaters shall not fall below the following values:												N/A
	- Heat pump space heaters and heat pump combination heaters, with the exception of low-temperature heat pumps: 100%												N/A
	- Low-temperature heat pumps: 115%												N/A
	(b) From 26 September 2017 the seasonal space heating energy efficiency and useful efficiencies of heaters shall not fall below the following values:												P
	- Heat pump space heaters and heat pump combination heaters, with the exception of low-temperature heat pumps: 110%												P
	- Low-temperature heat pumps: 125%												P
2	Requirements for water heating energy efficiency												N/A
	(a) From 26 September 2015 the water heating energy efficiency of combination heaters shall not fall below the following values:												N/A
	Declared load profile	3XS	XXS	XS	S	M	L	XL	XXL	3XL	4XL	-	
	Water heating energy efficiency	22%	23%	26%	26%	30%	30%	30%	32%	32%	32%		
	(a) From 26 September 2017 the water heating energy efficiency of combination heaters shall not fall below the following values:												N/A

COMMISSION REGULATION (EU) No 813/2013													
COMMISSION DELEGATED REGULATION (EU) No 811/2013													
Clause	Requirement - Test											Result - Remark	Verdict
	Declared load profile	3XS	XXS	XS	S	M	L	XL	XXL	3XL	4XL	-	
	Water heating energy efficiency	32%	32%	32%	32%	36%	37%	38%	60%	64%	64%	-	
3	Requirements for sound power level											P	
	From 26 September 2015 the sound power level of heat pump space heaters and heat pump combination heaters shall not exceed the following values:											P	
	Rated heat output ≤ 6 kW		6 kW < Rated heat output ≤ 12 kW		12 kW < Rated heat output ≤ 30 kW		30 kW < Rated heat output ≤ 70 kW					-	
	indoor	outdoor	indoor	outdoor	indoor	outdoor	indoor	outdoor	indoor	outdoor			
	60 dB	65 dB	65 dB	70 dB	70 dB	78 dB	80 dB	88 dB					
4	Requirements for emissions nitrogen oxides											N/A	
5	Requirements for product information											N/A	
	From 26 September 2015 the following product information on heaters shall be provided:											N/A	
	(a) the instruction manuals for installers and end-users, and free access websites of manufacturers, their authorised representatives and importers shall contain the following elements:											N/A	
	- For heat pump heaters and heat pump combination heaters, the technical parameters set out in Table 2, measured and calculated in accordance with Annex III;											N/A	
	- Any specific precautions that shall be taken when the heater is assembled, installed or maintained;											N/A	
	- Information relevant for disassembly, recycling and/or disposal at end-of-life;											N/A	
Annex III	Measurements and calculations											P	

COMMISSION DELEGATED REGULATION (EU) No 811/2013

Annex II	Energy efficiency classes											P
1	Seasonal space heating energy efficiency classes											P

